

PASSAIC VALLEY WATER COMMISSION
DATE: APRIL 24, 2026

CONTRACT #26-V-14
FURNISH AND DELIVER CORROSION INHIBITOR

NOTICE OF ADDENDUM NO.1

Bidders are advised that the original Contract Documents for the referenced Contract have been amended as noted in this Addendum No. 1. **This Addendum shall become part of the Contract Documents and is to be attached thereto. Bidders shall acknowledge receipt of this Addendum on page P-7 of the Bid Documents.** A copy of the Addendum may be obtained by contacting Ms. Lisa Bresemann at 973-340-4315 or via email at lbresemann@pvwc.com with the Purchasing Department of the Commission between the hours of 8:30 a.m. and 4:30 p.m., Monday through Friday (holidays excluded). The Bidders will be provided with a copy of the Contract Documents via email. Bidders who have already been issued the Contract Documents by the Owner will also be forwarded a copy of the Addendum.

FORM OF PROPOSAL

Replace Page FP-1 to FP-3 in its entirety with ADD1-FP-1 to ADD1-FP-4.

TECHNICAL SPECIFICATIONS:

Section 464516, Corrosion Inhibitor

Replace Page 464516-1, Part 2 A, in its entirety:

“A. All Product delivered under this Contract shall conform to the requirements in AWWA Standard B504, latest revision in effect at the time of bid, and shall meet the following typical physical properties and chemical analysis:

Option #1:

Orthophosphate as PO ₄	36% ± 2%
pH	4.3 ± 0.3
Density, Pounds/gallon	11.4

Option #2:

Orthophosphate as PO ₄	28.5% ± 2%
pH, 1% Solution	5.5 ± 0.5
Density, Pounds/gallon	11 ± 0.5

Addendum No. 1 includes miscellaneous changes and clarifications to the Contract Documents.

The specifications for the referenced contract are hereby amended by the Addendum. The Addendum shall be attached to and become part of the Contract Documents.